

Certification of Registration



POWER PROOF TRADING & CONTRACTING

ADDRESS: BINMAHMOUD AREA, AL- JEZEERA STREET, BUILDING NO-56,
FLOOR NO-03, OFFICE NO-303 DOHA, QATAR

QACS INTERNATIONAL

Certify that the quality management system of the above organisation has been audited and found to be in accordance with the requirements of standard detailed below.

ISO 9001:2015

BUILDING CHEMICALS MATERIALS & ADDITIVES FOR CONCRETE SOLUTIONS,
CONCRETE INJECTION MACHINES, CONCRETE INJECTION ACCESSORIES,
CONCRETE INJECTION RESIN, CONCRETE CORING, CONCRETE CUTTING,
CONCRETE REPAIR, CRACKS INJECTION, LIGHT WEIGHT CONCRETE,
FLOORINGS & COATINGS, CAR PARKING COATING, CONCRETE
GRINDING SCREED WORKS, SHOTCRETE WORKS

Certificate No:- QAIS-Q-QAT-PP-02.18.117

This certification was conducted in accordance with the qacs international f.z.c auditing and Certification procedures and it is remain valid subject to annual surveillance audits.

Certificate Issue Date: 23rd April 2018
Date of Initial Registration: 23rd April 2018
Certificate Validity:- 3 Years

1st Surveillance Date: 22nd April 2019
2nd Surveillance Date: 22nd April 2020
Recertification Date:- 22nd April 2021

Note: Certificate shall be valid after surveillance, only if continuation letter by QACS is present.

To Check the certificate validity please

Refer Web:- (www.qacsintl.ae).




Authorised Signatory



QACS International F.Z.C

Email id: info@qacsintl.ae, operationqacs@gmail.com
www.qacsintl.ae



قطر تستحق الأفضل
Qatar Deserves The Best

16/05/2019 11:25:22 AM



2019/0011596/5

السيد/ حافيير جوسانديس جونزالز
مدير العقود الإطارية
شركة ليكواس للتجارة والمقاولات
صندوق بريد: 209143 - الدوحة
فاكس رقم: 44157294

تحية طيبة وبعد ، ، ،

الموضوع: تقديم التسليم المواد لمشروع الطاقة 95

بالإشارة الي كتابكم رقم GTC101-LTC-PWA-0255 بتاريخ 09.05.2019 يرجى الإحاطة بأن مادة
Power Protect 095 Rev.2 المقدمة من طرفكم والمخصصة للحقن مقبولة لدينا.
لذا يمكنكم الاستمرار في العمل طبقا لشروط التعاقد

وتفضلوا بقبول فائق الاحترام

خالد احمد العبيدي
مدير ادارة تشغيل وصيانة شبكات الصرف الصحي



State of Qatar
Public Works Authority
Assets Affairs

This form is to be used for describing the review comments related to Contractor post contract award submittals of management plans, procedures, method statements, inspection test plans, risk assessments, pre-qualification, materials, mock ups, test reports, drawings, etc. that can lead to one of the following outcomes.

<input checked="" type="checkbox"/> Status A (Reviewed)	<input type="checkbox"/> Status B (Reviewed as noted)	<input type="checkbox"/> Status C (Revise and Resubmit)	<input type="checkbox"/> Status D (Cancelled)
Review Outcome			
A: Reviewed			

Response Date:	12-May-2019
Reviewed by:	Riza Ozan Goray
Checked by:	Mohd Radzi Bin Haji Othman
Review Reference:	QCS 2014, SIC_18 Framework Contract & ITQ

Contractor Submittal Details	
Project:	Sewer Inspection and Cleaning Services Framework (SIC_18) (AA-DOM 14/15 M 1646-4.07/G)
Client:	Ashghal
Consultant:	n.a.
Contractor:	
FCTS Submittal Reference:	2019_0002707_1 (GTC101-LTC-PWA-185)
Contractor Submittal Ref. & Rev.:	LTC-MAR-DOC-001 R2
Submittal Title:	Material Submittal for Injection (Power Protect O95, Power Proof)
Submission Date:	12/05/2019

No.	Related Section, Chapter, etc.	Remarks, Observations, Comments	Resolution	Status
1.0	ALL	No page no.'s, no document header & footer, table of content, section dividers, etc. Spelling checks & amendments needed throughout the document (i.e. "GEC", "Clnet", submittal number, etc.) 23-Apr-19 (FCTS Ref. 2019_0018690_1, GTC101-LTC-PWA-0235) Document quality improved.	REV.01: Material submittal revised as per the comments	C

Project Details

Document No:	DN107-P05-BTC-CON-MAR-G10233	Rev. No.:	00	Date:	16 July 2019
Project No:	IA 2016 C 066 G	Area:	Package 05		
Project Title:	Infrastructure FS Gaps for Bani HAJER Package 05 (P107-P05)				
GEC	HYDER Consulting Middle East Limited	Contractor:	Bin Omran Trading and Contracting Company		

We request the approval of the Engineer to supply the following materials for incorporation into the works

Part 1 - Material Particulars (one item per form)

Type of Material:	POLYESTER CRACK SEALER (POWER PROTECT O-95 & W-70)		<table border="1"> <tr><td>No.</td><td>2531</td></tr> <tr><td>Date Rec'd</td><td>16/7/19</td></tr> <tr><td>AM/AD</td><td>CB</td></tr> <tr><td>F.I.P.</td><td></td></tr> <tr><td>File</td><td></td></tr> <tr><td>Action</td><td>SJ-JR</td></tr> <tr><td>Copied to:</td><td></td></tr> </table>		No.	2531	Date Rec'd	16/7/19	AM/AD	CB	F.I.P.		File		Action	SJ-JR	Copied to:	
No.	2531																	
Date Rec'd	16/7/19																	
AM/AD	CB																	
F.I.P.																		
File																		
Action	SJ-JR																	
Copied to:																		
Area of Application:	INJECTION AND SEALING WATER LEAKS in the shafts																	
BoQ Ref:	Section 11	Drawing Ref:																
Specification:	QCS 2014 Section 8																	
Applicable Standards:																		
Country of Origin:	Qatar																	
Availability:	As Required																	

List and attach all relevant technical literature marked to identify relevant description, current test certificates, samples as appropriate

- Company Profile
- Certificates , Compliance Statement , Technical Data Sheet , Warranty Certificate
- Test Certificate , Country of Origin
- Sample Warranty Certificates , Project Reference List
- Previous Approval , Product Catalogues ,

Part 2 - Particulars of Manufacturer / Supplier

Company Name:	POWERPROOF TRADING AND CONTRACTING
Address 1:	Doha, Qatar P.O. Box 7643
Address 2:	
Address 3:	
Address 4:	
e-mail:	aya@powerproofqatar.com



Telephone No: +974-44883266/70009311

Part 3 - Particulars of Local Agent (if applicable)

Company Name:

Address 1:

Address 2:

Address 3:

Address 4:

e-mail:

Telephone No:

Part 4 - Delivery Details

Ex-Works Total Duration:

Latest Date for Order:

Date Material Required on Site:

Estimated Date of Arrival on Site:

We certify that the above submitted items have been reviewed in detail and are correct and in strict accordance with the contract drawings and specifications except as otherwise stated, and also that the material sources indicated above have been reviewed in detail and that we will supply the submitted items in full compliance with the schedule delivery plans

Name: ABDULSALAM AL DAMLAKHI

Signature:



Date: 16 JULY 2019

Part 5 - GEC Recommendation Comments

To Contractor:

NO COMMENT.

NOTE MUST RECORD WHERE THIS PRODUCT IS USED. INRS TO BE ISSUED FOR ALL REPAIRS. J. K. 20/07/19.

Action Code A:

Approved as Submitted

Action Code B:

Revise and Re-submit

Action Code C:

Rejected

Name:

Signature:

Handwritten signature



RE 20/7/19.

Footnote:

Approval by the GEC shall not relieve the Contractor of its obligations and liabilities under the contract or constitute authorization of any change to Contract Documents, and therefore, shall not imply any recognition whatsoever of additional time or cost to the contract.



17 April 2016

Ref.: M006-LBE-COM-LTR-01966

To: **AKTOR-L&T-YAPI-STFA-JEC-JV (ALYSJ JV)**
 Near Al Waab Petrol Station
 Behind Qtel Building
 Al Waab Street
 P.O. Box 24375, Doha, Qatar

Attention: Mr. Carlo Germani - Contractor's Representative

Project: Qatar Integrated Railway Project (QIRP) – Gold Line Underground - Contract No:
 RTC/ 040/2012

Subject: Approval request under Sub-Clause 4.7.3 – General Conditions of Contract for
 * Subcontractor: Power Proof Trading and Contracting for Floorings, Coatings, Light
 Weight Foamed Concrete and Screeding Works

The Engineer's Approval Request of local Subcontractors and Suppliers to carry out Lump Sum Works, all in accordance with Conditions of Contract Sub-Clause 4.7


SUBCONTRACTOR	✓	LUMP SUM	✓	LOCAL	✓	STAGE 1 (Add to App'd List)	N/A
SUPPLIER	N/A	PROVISIONAL SUM	N/A	INTERNATIONAL	N/A	STAGE 2 (App'd for duties)	✓
Scope	Subcontractor for Floorings, Coatings, Light Weight Foamed Concrete and Screeding Works						

We refer to your Subcontractor Approval Request (SAR) submission ref: M006-GDB-COM-SAR-00705 Rev.2 dated 31 March 2016.

Pursuant to the Conditions of Contract, Sub-Clause 4.7.3, the Engineer hereby approves **Power Proof Trading and Contracting** as an approved Subcontractor for Floorings, Coatings, Light Weight Foamed Concrete and Screeding Works as a part of the LUMP SUM work elements.

The Contractor's attention is drawn to Sub-Clause 4.7.5, which requires the Contractor to give 28 days' notice to the Engineer of the intended date of commencement of the Subcontractor's work and of the commencement of such work on the Site.

Yours faithfully,


Remy Vandebussche
 Engineer's Assistant

- Cc:**
- Saad Ahmed Al Muhannadi – Employer
 - Daniel Leckel – Engineer
 - Samuel Adair McChesney – Qatar Rail Project Director Sm
 - John Thomas Gillespie, Qatar Rail Contract Administration Manager

ALYSJ		Gold Line Underground		
NAME	DATE	ACTION	INFO.	F-LIP
Craig H			✓	
Ismael G			✓	
Richard M			✓	
M. Sh. Hub			✓	

Enclosed: Qatar Rail Document Review Sheet (1 page)


Response required on or before: N/A

RDA/AQU

Acknowledged by

Qatar Rail
Document Review Sheet (Engineer)

Company Management System

PROJECT:		Gold Line Metro		PROJECT NO.:		M006	
DRS NUMBER:		M006-COM-ERS-00293		REV.:		2	
ORIGINATOR:		ALYSJ JV		DATE:		14-Apr-16	
DOCUMENT NO.:		M006-GDB-COM-SAR-00705		TRANSMITTAL NO. / DATE:		M006-GDB-WTRAN-135298/ 31 March 2016	
DOCUMENT TITLE:		Subcontractor Approval Request for Power Proof Trading and Contracting – Floorings, Coatings, Light Weight Foamed Concrete and Screeding Works (LS)		DISCIPLINE:		Commercials	
DOCUMENT TYPE:				Supplier / Sub Contractor Approval Request			
Comment Code Legend (for individual comments):				Reply Code Legend			
1 = Action required for this issue 3 = to be addressed at DD2				i=incorporated, ii= evaluated and not incorporated for reason stated			
2 = advisory comment				Open/Closed			
No.	Initial	Page/Section	Comment Code	Reviewers Comments (PMC/CPO, CTO)	Reply Code	D&B Contractor/Other Party Reply	Reply Status by Reviewer
1	MMM	General	1	The proposed subcontractor is approved but for Tunnel and Cross Passage associated works. Please define clear scope of works.	i	Please be informed that the proposed Company is intended to be used in Stations and in Subways <u>only</u> , for Floorings, Coatings, Lightweight Foamed Concrete and for Screeding Works as a part of Lump Sum (LS) work element. Note: The Company's scope was also modified in page 3/3 accordingly.	Closed
2	RDA	General	2	Please note that no Sub contractor/ Supplier are allowed to participate to the project until receiving the Engineer's prior written approval as per GCC Sub Clause 4.7.3 <u>corroborated</u> with the Contractor's notice required under GCC Sub clause 4.7.5.	i	In accordance with your comment; Please be informed that this SAR submission is also a notice under Sub-clause 4.7.5 of Contract RTC/040/2012 for Qatar Rail Integrated Railway Project (QIRP) – Gold Line Underground that the intended date of commencement of above mentioned Subcontractor is 28 days from the date of this SAR submission.	Closed
Status Code Legend:							
Document Review Status Code:		A		A. Approved		C. SONO	
				B. Approved with comments		D. NOWC: No Objection with comments	
						E. Fail/Not approved	
						F. Responded/Reviewed/Actioned	
Reviewer's Name		Position		COMMENTS/STATUS RECOMMENDED BY PMC		COMMENTS/STATUS RECOMMENDED BY CTO	
Name:		Position:		Name:		Position:	
Maung Maw		Sr. Tunneling Er.		Paul Hegarty			
Dan Radu		Contract Administrator		Commercial Manager			
Date:		Date:		Date:		Date:	
14-Apr-16		14-Apr-16		18-Apr-2016			
Name:		Position:		Name:		Position:	
Remy Vanderbussche		Project Director		Carlo Germani		Project Director	
Signature:		Signature:		Signature:		Signature:	
							



Date : 29-04-2019	MATERIAL SUBMITTAL	Submittal No. : FLK-DMS-2019-0477
PROJECT TITLE	FIRE FIGHTING INFRASTRUCTURE AT MAIN CAMPUS	
CONTRACT NO.	EIN/190/3014	
CONTRACTOR	FIRELINK	
DISCIPLINE :	CIVIL	
SUB CONTRACTOR	AL HUDA	

Material Description		
Material Name	Water Leakage Injection Chemical – Power Protect O-95 (including method statement)	
B.O.Q. Ref.	N/A	
Manufacturer:	Power Proof Trading & Contracting	Country of Origin: Qatar
Supplier Name:	Power Proof Trading & Contracting	Agent Name: Power Proof Trading & Contracting
Literature :	YES	Sample: NO
Fully Complies to Specifications: YES	Fully Complies to Design Drawings: YES	Fully Complies to Technical Requirements: YES

In case of Non Compliance to any of the above items contractor to provide details of Non Compliance & Justification. IF not provided the Approval is Not Valid

Contractor Signature:		Stamp:	
-----------------------	--	--------	--

Consultant Discipline Engineer Comments/ Acceptance:

- submit the updated test report for density, reaction time and specific gravity.
- final approval after finished injection with inspection request.
- final approval after finished leakage test successfully.
- strictly follow the method of statements per recommendation by manufacturer.

Approval Status: (XWC)

Name : Priscilla
Signature : [Signature]
Date : 11/5/19

Consultant Project Manager Comments/ Acceptance :

As above.

Approval Status: Approved with Comments

Name : Neeraj
Signature : [Signature]
Date : 12/5/19

QU Comments / Acceptance :

Name : _____
Signature : _____
Date : _____

Approval Status: _____

QU Decision :

<input type="checkbox"/>	APPROVED	Date : _____
<input type="checkbox"/>	APPROVED WITH COMMENTS	Signature: _____
<input type="checkbox"/>	REVISE & RESUBMIT	
<input type="checkbox"/>	NOT APPROVED	



Material Transmittal

Project Name: AL NASSEM TOWER at AL KHARAJ RES/19, LUSAIL **AOT** Project No: AK-RES/19
 Owner: KHALID MOHAMED A AL-ATTEYAH Submittal No.: AS-ANT-MT-MZP-037 Rev.02 A
 Date: 24 / 04 / 2018
 Contractor's Representative Printed Name & Signature: *[Signature]*
 Prepared by: Engr. Mike Belegado Engr. Omar Kassem
 QA/QC Engineer Technical Engineer
 Submitted by: Engr. Mahmoud Omar
 Project Manager

24 APR 2018
 Received by: 14:57 Site Supervision
 Time: 14:57

Description:
MATERIALS SUBMITTAL OF POWER-PROTECT O-95 FOR INJECTION CHEMICAL @ SWIMMING POOL WATER LEAKAGE
1. COMPLIANCE FOR CONSULTANT COMMENTS
2. SPECIFICATION COMPLIANCE STATEMENT
3. COMPANY PROFILE
4. MATERIAL TECHNICAL SUBMITTAL
POWER-PROTECT O-95
 • METHOD OF STATEMENT
 • MATERIALS DATA SHEETS
 • MATERIALS SAFETY DATA SHEETS
 • MATERIALS TEST REPORT
 • MATERIALS CONSULTANT APPROVAL

Drawing Ref: _____
 Specification Ref: _____
 Bill of Quantities Ref: _____
 Other Ref: _____

MZP SITE SUPERVISION DEPARTMENT		
Date:		
Discip.	Act.	Info.
P.M.		
Arch.		
Civil		
Mech.		
Elect.		
I.D.		
Planner		
Q.S.		
Head Office		
H.S.E.		
Sec/DC		
M/FILE		
Samples		
S/FILE		
RECEIVED: <i>[Signature]</i>		

[Handwritten] 25/4/2018
 25/4/18

Attachment: Literature/Catalogue Test Certificates
 Manufacturer/Supplier: From Approved Vendor List Equivalent or Approved

Name of Manufacturer/Supplier: POWER PROOF
 Address: PO BOX 7643 Doha, Qatar Local Agent: POWER PROOF
 Agent Tel. No.: +974-55897238 email add: infopowerproofqatar.com Tel No: +974 44883266
 Delivery: As Required Country of Origin: QATAR
 Availability: Locally Manufactured: Overseas:
 Manufacturer: Production Period: Delivery ex Work: Total Delivery Unit:
 Mode of Transport: Overland: Air Freight: Sea Freight:
 Programme: Latest Date of Orders: Date Material Required: Expected Date on Site:
 Approved as noted: Rejected: Additional Info. Required: Others:

Comments:
 - STRUCTURALLY WE HAVE NO OBJECTION, SUBJECT TO:
 1) COMPLIANCE TO MANUFACTURER'S RECOMMENDATION.
 2) APPROVAL OF MTR.
 MECH: No technical objection:
 subject to compliance with manufacturer standards & recommendations
 subject to testing & commissioning approval.
 Consultant: *[Signature]* 25.04.18
 Owner: Engineering Department Comments (if applicable)

Printed Name: _____ Signature: _____
 Received by: (Contractor) _____
 Printed Name: _____ Signature: _____

AL SEAL CONTRACTING & TRADING CO.
 AL NASSEM TOWER PROJECT
 25 APR 2018
 11:15 am
 RECEIVED
 By: _____



MATERIAL SUBMITTAL



BY: M.S. g: isam

Date : 11-Jun-19 NEW SUBMITTAL RESUBMITTAL

Project Name : (214) RESIDENTIAL BUILDINGS Submittal No.: HCC-CEG-H31-MAT-CV-017

Project No. : H31 Rev: 00

Customer : SHK. ABDULLAH BIN KHALID BIN HAMAD AL THANI ARC CIVIL ELE MECH

DESCRIPTION Drawing Ref.

WATER TANK INJECTION Specs. Ref.

(POWER-PROTECT T-0-95) BOQ Ref.

Attachment Literature Test Certificates Samples

B.S. Ref.

MANUFACTURER/SUPPLIER

POWER PROOF

Address: DOHA QATAR

APPLICATOR M/S. SPECIALIZED FOR INSULATION MATERIALS CO.

Post Box -DOHA-QATAR Telephone No. +974 44691438 Fax No. +974 44691433

DELIVERY

AVAILABILITY		MODE OF TRANSPORT	
Locally Manufactured	<input checked="" type="checkbox"/>	Overland	<input type="checkbox"/>
CCASG Manufactured	<input type="checkbox"/>	Air Freight	<input type="checkbox"/>
Overseas	<input type="checkbox"/>	Sea Freight	<input type="checkbox"/>
MANUFACTURE		PROGRAMME	
Production Period	<input type="checkbox"/>	Latest Date for Order	<input type="checkbox"/>
Delivery Ex. Works	<input type="checkbox"/>	Date Material Required on Site	<input type="checkbox"/>
Total Delivery Time	<input type="checkbox"/>		

The Contractor certifies that the submitted items have been reviewed in detail and are correct and in strict conformance with the Contract documents except as otherwise stated.

CONSULTANT COMMENTS

- | | | |
|---|--|---|
| (1) Approved <input type="checkbox"/> | (4) Revise & Re-submit <input type="checkbox"/> | (7) Mnfctr./ Supplier <input type="checkbox"/> |
| (2) Approved as Noted <input checked="" type="checkbox"/> | (5) Add'l. Info Required <input type="checkbox"/> | (8) Guarantee Required <input type="checkbox"/> |
| (3) Rejected <input type="checkbox"/> | (6) Sample/ Test Required <input type="checkbox"/> | (9) Others <input type="checkbox"/> |

REMARKS - Final approval of this material shall be after the complete disappearance of water leaks and the concrete surface is totally dry.

Signature: *[Signature]* / M. VALENZONA Date: 12 June 2019 *[Signature]*

CUSTOMER/ENGINEERING DEPARTMENT COMMENTS

Engr. Nader Ahmed Miri (Project Manager)
Signature: *[Signature]* Date: 11-Jun-19

Approval by the Consultant or the Customer shall not relieve the Contractor of his obligation under the Contract, and the Contractor shall be solely responsible for the soundness and correctness of the submitted materials and documents.

For Contractor Use

For Consultant Use

For Customer Use

 <p>دوحة فستيفال سيتي Doha Festival City</p>	Project Name : DOHA FESTIVAL CITY - 3100 MALL MAIN CONTRACT Project No. : 796/09 Form No. : AEB-CSD-P07-F14 Rev. 0 Feb. 2012		
	Client: Bawabat Al Shamal Real Estate Co. WLL (BASREC)	Project Manager: 	Consultant:  المكتب العربي للشؤون الهندسية Arab Engineering Bureau

DOCUMENT SUBMITTAL FORM

Submittal Type : <input type="checkbox"/> - Technical Submittals <input type="checkbox"/> - PQP / ITP <input type="checkbox"/> - Test Reports <input type="checkbox"/> - Design Data <input type="checkbox"/> - Certificates	<input type="checkbox"/> - Procedures <input type="checkbox"/> - Supplier Approval <input type="checkbox"/> - Subcon Approval <input type="checkbox"/> - Method Statement <input type="checkbox"/> - Schedule / Reports	<input checked="" type="checkbox"/> - Others	Submittal No. : 3100-GCC-ALEC-JV-DS-01535 Rev.: 0 Submittal Date : 26/03/17 Expected Response Date : _____
No. of Sets: a.) Hardcopy 1 SET Size: A4 b.) E-copy _____ Type: _____			

Discipline:




- Civil / Structural
 - Mechanical
 - Electrical
 - Architect / Interior Design
 - Others
 Contractor Others _____

Description of Documents:

MATERIAL DATA SHEETS FOR
POWER PROTECT 0-95, POWER PROTECT W-70, INJECTION PACKERS, INJECTION MACHINE, POWER PROTECT MSDS
(FOR INFORMATION ONLY)

Submitted for :

- Review and Approval
 - Re-Submitted for Review & Approval
 - For Information & Records

Prepared by:  K. RAGHUNATH / 26.03.2017 Name / Sign / Date	Reviewed by: (Contractors Proj. Coordinator or QA/QC)  PRAVEEN MANI / 26.03.2017 Name / Sign / Date	Recommended for Submission by: (Contractors PM)  THEUNS ERASMUS / 26.03.2017 Name / Sign / Date
--	---	---

COMMENTS BY THE CONSULTANT (Use Review Comment Sheet When Necessary)

Submittal Status :

- Approved
 - Approved as Noted
 - Revise and Resubmit
 - Rejected

Reviewed by: _____ Name / Signature AEB Engineer Designation Date	Approved by: _____ Name / Signature AEB - LRE or RE Designation Date	Client Rep. Endorsement (when required): _____ Name / Signature Designation Date
--	---	---

Note : Approval or comments made to this submittal does not relieve the Contractor from their responsibilities. The assessment is to review the general conformance and compliance of the submittals to the contract and specification requirements.



Construction, Completion and Maintenance of General Takaful C-Ring Road Office Building (4B+G+2)



DOCUMENT REVIEW SHEET

PROJECT:		CONSTRUCTION, COMPLETION AND MAINTENANCE OF GENERAL TAKAFUL C-RING ROAD OFFICE BUILDING (4B+G+2)		DATE: 11/02/2017	
TRANSMITTAL NUMBER		C-270/OE/KA/EF/TN/824		DOCUMENT REVISION : 00	
DOCUMENT TITLE		MATERIAL APPROVAL REQUEST FOR OIL - BASED POLYURETHANE FOAM INJECTION RESIN POWER - PROTECT 0 - 95 (WATERPROOFING)			
DISCIPLINE		<input checked="" type="checkbox"/> CIVIL <input type="checkbox"/> ELECTRICAL <input type="checkbox"/> MECHANICAL <input type="checkbox"/> STRUCTURAL <input type="checkbox"/> ARCHITECTURAL <input type="checkbox"/> OTHERS			
SL.NO.	DOCUMENT / DRAWING NO.	REV.NO.	SECTION	COMMENTS BY K&A	RESPONSE BY
1.	OE-CIV-MAT-081	00		<ul style="list-style-type: none"> To follow the manufacturer recommendations. To demonstrate mock up sample at site in presence of manufacturer technician. Subject to site condition. 	
<input type="checkbox"/> APPROVED <input type="checkbox"/> NOT APPROVED <input checked="" type="checkbox"/> APPROVED AS NOTED <input type="checkbox"/> REVISE & RESUBMIT					
Reviewed By: Name: <i>BASSEM KARAM</i>		Designation: <i>RE + PM</i>		Signature: 	
				Date: <i>11.02.2017</i>	



Project	AL KHARAEJ-RES 20, RESIDENTIAL TOWER @ LUSAIL																							
MATERIAL SUBMITTAL																								
Submittal No.	ALSEAL-AK-MS-ST-0024	Rev	00	X	New submittal	Date	14 APRIL 2018																	
Material Description	MATERIAL SUBMITTAL FOR WATER LEAKAGE INJECTION CHEMICAL - POWER-PROTECT O-95																							
Country of Origin	QATAR	Specified	X	Alternative		Architecture	Structure	X																
						Electrical	Mechanical	Other																
Manufacturer	POWER PROOF	Local Supplier/Agent	POWER PROOF	Details																				
Name				MATERIALS SUBMITTAL OF POWER-PROTECT O-95 FOR WATER LEAKAGE INJECTION CHEMICAL 1. COMPANY PROFILE 2. MATERIAL TECHNICAL SUBMITTAL 3. POWER-PROTECT O-95 4. METHOD OF STATEMENT 5. MATERIALS DATA SHEETS 6. MATERIALS SAFETY DATA SHEETS 7. MATERIALS TEST REPORT 8. MATERIALS CONSULTANT APPROVAL 9. COMPLIANCE FOR CONSULTANT COMMENTS 10. SPECIFICATION COMPLIANCE STATEMENT																				
	+974 44883266		+974 44883266																					
Tel	PO BOX 7643 Doha, Qatar	PO BOX 7643 Doha, Qatar																						
Fax																								
POBox																								
EMAIL																								
BOQ		BS	Specs	Attached: Hard Copy (3Nos.) & Soft Copy (1Nos.)																				
Drawings ref.	<table border="1"> <thead> <tr> <th>Attached</th> <th>Data Sheet</th> <th>Sample</th> <th>Catalogue</th> <th>Profile</th> <th>Calculation</th> <th>Test Results</th> <th>Other</th> </tr> </thead> <tbody> <tr> <td></td> <td>X</td> <td></td> <td>X</td> <td>X</td> <td></td> <td>X</td> <td>X</td> </tr> </tbody> </table>								Attached	Data Sheet	Sample	Catalogue	Profile	Calculation	Test Results	Other		X		X	X		X	X
Attached	Data Sheet	Sample	Catalogue	Profile	Calculation	Test Results	Other																	
	X		X	X		X	X																	
Prepared by: QA/QC Dept	Checked & verified by: Technical Dept.			Project Manager:																				
Eng. SHAMNAS	Eng. OMAR KASSEM			Eng. MAHMOUD OMAR																				
Name	Received by Consultant			Date																				
	Signature			16 APR 2018																				
Consultant comments:																								
By:																								
<input checked="" type="checkbox"/> Approved	<input checked="" type="checkbox"/> Approved With Comments	<input type="checkbox"/> More Information Required		<input checked="" type="checkbox"/> Rejected																				
Commented by		Name		Signature		Date																		
QA/QC																								
Project Manager																								
Received Back By the contractor																								

United Consultants

Architectural, Structural, Mechanical & Electrical Consultants



الشركة الدولية للتدوير والمقاولات
International Dec. & Cont. Co.
Tel.: 4440350 - Fax: 4421654 P.O. Box: 4013, Doha, Qatar



الاتحاد للاستشارات

الهندسية

استشاريون-معماريون-إنشائيون-كهرباء-ميكانيكا

MATERIAL SUBMITTAL No .125 Rev 01

Date	: 24/01/2017
Project Title	: Al Rabban Establishment Building (2B+G+M+7) Farij Bin Mahmoud
Contractor	: International Decoration & Contracting Co.
Owner	: Al Rabban Establishment Building (2B+G+M+7) Farij Bin Mahmoud
Sub-Contractor	:
Manufacturer	:
Supplier Name	: Power Proof Trading & Contracting
Literature	: Concrete injection :- - Power Protect O-95 - Power Protect W-70
Contractor Signature	:
Country of Origin:	
Agent Name : Power Proof Trading & Contracting	
Sample:	
Stamp:	
Consultants Comments:	
Architectural:	A B D E F G
Structural: Approved as Notes	A B C D E F G
* final Approval with inspection in site After finish injection	A B C D E F G
Mechanical: * final Approval After finish leakage	A B C D E F G
Electrical:	A B C D E F G
Client's Signature (Acknowledgment & Approval)	Contractor's Receipt
Signature:	Signature:
Date: 26/11/2017	Date:

Received Date: 29-1-17
Received By:
Pass to: Action Note
Civil Engr.
Technical Engr.
Account
Safety
Name & Signature
Date

- A. Approved
- B. Approved as Noted
- C. Revise & Resubmit
- D. Rejected
- E. Additional info. Required
- F. Samples Required
- G. Test Required

Approval by Consultants/Client shall not relieve the Contractor from this obligations under the Contract, the Contractor shall be solely responsible for the soundness and correctness of the submitted materials and/or documents.



SPECIFICATION COMPLIANCE STATEMENT

New Port Project Steering Committee

NPP Port Infrastructure & Buildings Package NPP0057

Contractor : Sinohydro - United Construction Est. - JV

Material: Concrete Crack Injection (Wet Cracks)

NO.	PROPERTIES	QCS SPECIFICATION	TESTED VALUES	COMPLIANCE		REMARKS
				YES	NO	
REFERENCE: QCS 2010 SECTION 5, PART 16.6.6, TABLE 16.6						
1	Description	Polyurethane foaming crack injection resin	Polyurethane foaming crack injection resin	Yes		
2	Elongation at Break	60% (ASTM D638 or Equivalent)	62%	Yes		Check the attached Accos Test Report No: 17084015 Rev-1
3	Modulus of Elasticity	4MPa (DIN53457 or Equivalent)	4.69 Mpa	Yes		Check the attached Accos Test Report No: 17084015/2 Rev-1
4	Shore A Hardness	4MPa (ASTM D2240 or Equivalent)	A/64/1	Yes		Check the attached Accos Test Report No: 17084015/3 Rev-2

